



July 23, 2026

DOMINIQUE DEVANEY
IDLEDALE WSD - PWSID C00130055
7555 E HAMPDEN STE 501
DENVER CO 80231

RESCIND OF TIER 1 BOIL WATER ADVISORY

Dear DOMINIQUE DEVANEY:

The Colorado Department of Public Health and Environment-Water Quality Control Division (the "Department") issued a "Boil Water Advisory" for the IDLEDALE WSD (the "Supplier") on **July 18, 2026** due to a line break resulting in a loss of pressure to the system. Loss of pressure may allow disease-causing organisms to enter the water system.

Since the "Boil Water Advisory" was issued, the Department has received the following information from the Supplier:

- The Supplier flushed the system and average system chlorine residuals were brought down to normal levels after the flush.
- The Supplier provided a written description of flushing activities and confirmation that the lowest chlorine residual is at the ends of the system.
- Confirmation that the samples taken were free from the presence of total coliform bacteria.

Based upon the actions taken by the Supplier, the "Boil Water Advisory" is hereby rescinded. Effective date of this action is **July 23, 2026**. The affected customers should be notified of the lifting of the "Boil Water Advisory." Public notice of the lifting of the "Boil Water Advisory" should include contact information for the water system and should be provided in a similar manner to which the initial advisory was issued. A template can be created at wqcdcompliance.com/pn under "Problem Corrected".

Please note, rescindment of the "Boil Water Advisory" does not constitute compliance with public notification requirements. If not already completed, the Supplier must submit the certificate of delivery and copy of the original public notice to fulfill the regulatory public notification requirements for the "Boil Water Advisory".

Some of the letter's content may not be fully accessible. If you encounter any accessibility barriers with this letter, please contact us at <https://cdphe.colorado.gov/accessibility>.

If you have any further questions, please contact me at 720-255-1296 or via email at ian.sutton@state.co.us.

Sincerely,

Ian Sutton
Review Engineer Work Lead
Water Quality Control Division
Colorado Department of Public Health and Environment

ec:

DOMINIQUE DEVANEY - dominique@publicalliancellc.com;
PAUL E GRANT II - p.grant@headwaysconsultants.net;
PUBLIC ALLIANCE LLC - dominique@publicalliancellc.com;
Christine Billings - cbilling@jeffco.us; Jefferson County Public Health
Jim Rada - jrada@jeffco.us; Jefferson County Public Health
Mitch Brown - mlbrown@jeffco.us; Jefferson County Public Health
Nicole Rowan, Water Quality Control Division Director, CDPHE
Ron Falco, WQCD SDW Program Manager
Tyson Ingels, WQCD Watershed & Engineering Program Manager
Michael Roach, WQCD CW Permitting and Compliance Program Manager
MaryAnn Nason, WQCD Operations Program Manager
Heather Young, WQCD FSS Manager
Nicole Graziano, WQCD DWCAS Manager
Jorge Delgado, WQCD DWCAS Compliance North Unit Manager
Robert Pohl, WQCD DWCAS Compliance South Unit Manager
Stephanie Hosie, WQCD MHP Unit Manager
Emily Clark, WQCD DW Enforcement Unit Manager
Lindsey Fettig, WQCD DWCAS Compliance North Lead
Ben Keilly, WQCD DWCAS Compliance South Lead
Kaitlyn Beekman, WQCD Communications and Special Projects Unit Manager
Drinking Water Acute Response Team Leads, WQCD
Sean Scott, DEHS, CDPHE
Henry Mitchel. Office of Emergency Preparedness and Response, CDPHE
Curt Drennen, Office of Emergency Preparedness and Response, CDPHE
Jeff Lundin Office of Emergency Preparedness and Response, CDPHE
Angela Strand, Office of Emergency Preparedness and Response, CDPHE
Office of Emergency Preparedness and Response Field Managers, CDPHE
Enteric Waterborne Disease Team, DCPHR, CDPHE
Christina Postolowski, Mobile Home Park Oversight Program, DOLA, MHPOP@state.co.us
Tessa Cole - NORTH - A SW WQCD DWCAS Compliance Specialist

File: CO0130055, JEFFERSON, Community - Groundwater UDI Surface Water